

Seattle Fire Department Permit Application
Code 5201 Motor Vehicle Fuel-Dispensing Facility (UST)

Level I
--Revised 1/2005--



Permit Fee: \$152.00

TO BE COMPLETED BY PERMIT APPLICANT (PLEASE PRINT)

FIRM NAME		
MAILING ADDRESS	SUITE	
CITY	STATE	ZIP
OPERATION ADDRESS		
CONTACT PERSON	PHONE NUMBER ()	

Please include a check made payable to the CITY OF SEATTLE with this application.

Permit applications may be submitted in person weekdays from 8:00 a.m. to 4:30 p.m., or mailed to:

Seattle Fire Department
Fire Marshal's Office—Permits
220 Third Avenue South, Second Floor
Seattle, WA 98104-2608

Permit processing: (206) 386-1025
www.seattle.gov/fire

TO BE COMPLETED BY INSPECTING ENGINE/LADDER COMPANY:

TYPE OF MATERIAL	AMOUNT	LOCATION
Example: Class I flammable liquid	4 x 18,000 gallons	Underground tanks
<input type="checkbox"/> Permit Conditions Approved		
Inspected By:	C/P/O:	SFD ID#:
Station No.	Occ. No.:	Date:
Special Permit Conditions: (continue on back if necessary)		

FMO OFFICE USE ONLY:

Date Received:	Receipt No.:	Check No.:
Expiration Date with Existing Permits:		Application ID#
<input type="checkbox"/> Cancel with full refund <input type="checkbox"/> Cancel, no refund <input type="checkbox"/> Moved <input type="checkbox"/> No Longer Needs <input type="checkbox"/> Out of Business		

PERMIT CONDITIONS

1. Dispensing devices shall be located as follows:
 - Ten feet or more from property lines,
 - Ten feet or more from buildings having combustible exterior wall surfaces or buildings having noncombustible exterior wall surfaces that are not part of a one-hour fire resistance-rated assembly or buildings having combustible overhangs,
 - Such that all portions of the vehicle being fueled will be on the premises of the fuel-dispensing facility,
 - Such that the nozzle, when the hose is fully extended, will not reach within 5 feet of building openings, and
 - Twenty feet or more from fixed ignition sources. (2003 SFC 2203.1)
2. All dispensing devices shall be protected against physical damage by mounting on a concrete island 6 inches or more in height or by other approved methods. (2003 SFC 2206.7.3)
3. An approved, clearly identified and readily accessible emergency disconnect switch shall be located within 100 feet of, but not less than 20 feet from dispensers. Such switch shall be distinctly labeled "EMERGENCY FUEL SHUTOFF". (2003 SFC 2203.2)
4. Warning signs shall be conspicuously posted within sight of each dispenser in the fuel dispensing area. Each sign shall:
 - prohibit smoking,
 - prohibit dispensing into unapproved containers,
 - prohibit filling of portable containers that are located inside trucks, passenger compartments or truck beds of any vehicle, and
 - require vehicle engines to be shut off during fueling (2003 SFC 2205.6)
5. Portable fire extinguishers having a minimum rating of 2A-20BC shall be provided and located such that an extinguisher is not more than 75 feet from any pump, dispenser or storage tank fill-pipe opening. The location of extinguishers shall be clearly identified with a sign. (2003 SFC 2205.5)
6. An accurate daily fuel inventory shall be maintained and made readily available to Fire Department personnel upon request. (2003 SFC 2206.2.1.1)
7. Weeds, grass, brush, trash and other combustible materials shall be kept at least 10 feet away from fuel-handling equipment. (2003 SFC 2205.7)
8. Class I, II or III-A liquids shall not be dispensed into portable containers unless such container is of approved material and construction, and has a tight closure with screwed or spring-loaded cover so designed that the contents can be dispensed without spilling. (2003 SFC 2204.4.1)
9. A listed automatic-closing-type hose nozzle valve having an integral latch-open device that disengages when the nozzle is returned to the dispenser shall be provided. (2003 SFC 2206.7.6)
10. Dispenser hoses shall be a maximum of 18 feet in length unless approved. When not in use, hose shall be reeled, racked or otherwise protected from damage. (2003 SFC 2206.7.5)
11. Unattended facilities shall be provided with a telephone not requiring a coin to operate or other approved, clearly identified means to notify the fire department in case of emergency. (2003 SFC 2204.3.6)
12. In addition to the signs required above, an emergency procedure sign shall be conspicuously posted at unattended facilities. Such signs shall read: (2003 SFC 2204.3.5)

IN CASE OF FIRE, SPILL OR RELEASE

1. USE EMERGENCY PUMP SHUTOFF

2. REPORT THE ACCIDENT!

FIRE DEPARTMENT TELEPHONE NUMBER _____

FACILITY ADDRESS _____